



LEARN MORE AT  
energystar.gov

# ENERGY STAR<sup>®</sup> Statement of Energy Performance

# 98

ENERGY STAR<sup>®</sup>  
Score<sup>1</sup>

## Benchmark Building

**Primary Property Function:** Office  
**Gross Floor Area (ft<sup>2</sup>):** 87,354  
**Built:** 1997

**For Year Ending:** May 31, 2013  
**Date Generated:** August 07, 2013

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

### Property & Contact Information

**Property Address**  
Benchmark Building  
3427 Any Street  
San Francisco, California 94109

**Property Owner**  
Benchmark Building  
3427 Any Street  
San Francisco, CA 94109

**Primary Contact**  
Justin Tiedemann  
201 Spear Street  
Suite 1100  
San Francisco, CA 94105  
415-830-9360  
justin@ecosminc.com

**Property ID:** 5439874

### Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison		
75.0 kBtu/ft <sup>2</sup>	Electric - Grid (kBtu)	1,206,456 (31%)	National Median Site EUI (kBtu/ft <sup>2</sup> )	107
	Natural Gas (kBtu)	2,664,744 (69%)	National Median Source EUI (kBtu/ft <sup>2</sup> )	182
			% Diff from National Median Source EUI	-49%
<b>Source EUI</b>		<b>Annual Emissions</b>		
97.4 kBtu/ft <sup>2</sup>		Greenhouse Gas Emissions (MtCO <sub>2</sub> e/year)	247	

### Signature & Stamp of Verifying Professional

I Justin Tiedemann verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

#### Licensed Professional

Justin Tiedemann  
201 Spear Street  
Suite 1100  
San Francisco, CA 94105  
415-830-9360  
justin@ecosminc.com



Professional Engineer Stamp  
(if applicable)